



Český metrologický institut

Okružní 31, 638 00 Brno

tel. +420 545 555 111

www.cmi.cz

Laboratory: Regional inspectorate, Okružní 31, 638 00 Brno
Department of primary metrology of liquids flow, flow velocity and heat, tel. +420 545 555 111, fax. +420 545 555 183

CERTIFICATE

6015-CC-P3005-26

Date of issue: August 14, 2026

Page 1 of 1

Czech Metrology Institute confirms the tests in accordance with EN 16321-1:2013 for the following petrol vapour recovery system

Type of system:	Vapour recovery system with electronic controlled proportional valve
Nozzle:	ELAFLEX ZVA Slimline 2 GR, 3 GR, ELAFLEX ZVA 200 GR
Hose assembly:	ELAFLEX Slimline 21/8, ELAFLEX Conti Slimline 21/8
Control unit:	TATSUNO EUROPE, type PDEX / TBELTx / PDEX5
Proportional valve:	ASCO, type EMXX
Vapour recovery pump:	RAEL, type RAEL VR PUMP

The following general conditions must be observed during installation:

Maximum volumetric fuel-flow rate:	45 l/min
Maximum back pressure in petrol vapour pump outlet line with maximum vapour flow:	50 mbar
Correction factor for system settings with simulated petrol-flow of 38 l/min:	1,12

Under the above specified conditions of installation approved by tests according to EN 16321-1 the efficiency of petrol vapour capture for mentioned vapour recovery system is in accordance with the requirement of Article 4 of Directive 2009/126/EC and Directive 2014/99/EU as amended (the minimum required efficiency $\geq 85\%$).

Date of tests: 7.7. – 10. 7. 2026

Tested by:

Ing. Peter Škrovánek



Head of the Department:

Mgr. Jindřich Bílek, PhD.